



OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on April 13, 2007.

ARCH CHEMICALS, INC.
501 MERRITT 7
P.O. BOX 5204
NORWALK, CT 06856-5204
203-229-3510

Facility: WOBURN, MA

Mechanical Devices

Trade Designation	Size	Water Contact Temp	Water Contact Material
Chemical Feeders ^[1]			
Constant Chlor Plus M3C-1S	N/A	CLD 23	MLTPL
Constant Chlor Plus MC-2S	N/A	CLD 23	MLTPL

[1] Certification of this product has been performed to the health effects requirements of NSF/ANSI Standard 61, which assesses the acceptability of potential extractants from the chemical generator. No evaluation has been performed on the strength or efficacy of the chemical(s) generated. As unit operation, maintenance and the consistency of source ingredients may affect the performance of the unit, the ensuing chemical(s) is not Certified by NSF to NSF/ANSI Standard 60.

Certified for maximum 1.7% calcium hypochlorite solution added to drinking water to effect a maximum use level (MUL) of 10 ppm total chlorine, with a minimum of 200,000 gallons of water treated per day.

Facility: ROCHESTER, NY

Mechanical Devices

Trade Designation	Size	Water Contact Temp	Water Contact Material
Chemical Feeders			
Constant Chlor Plus Briquette Chlorinator	3' x 4'	CLD 23	MLTPL

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.